



HP State Pollution Control Board

HIM Parivesh Bhawan, Phase-III, Below BCS, New Shimla-09

Phone No. 0177-2673766, 2673020 FAX-0177-2673018

Public Notice

Whereas in view of notification no. S.O. 4(E) dated 01/01/2016 of the Ministry of Environment, Forest and Climate Change, Govt. of India it has been stated that *“For each Common Effluent Treatment Plant (CETP), the State Board will prescribe Inlet Quality Standards for General Parameters, Ammonical Nitrogen and Heavy metals as per design of the Common Effluent Treatment Plant (CETP) and local needs & conditions.”*

Whereas, a committee comprising of Sr. Environmental Engineer, HPSPCB, Parwanoo, Sr. Scientific Officer, HPSPCB, Regional Lab, Shimla, Asstt. Environmental Engineer, HPSPCB, Head Office Shimla and Jr. Environmental Engineer, HPSPCB, RO Shimla was constituted by this office on 10-09-2020 for drafting and finalizing the inlet quality standards for the proposed CETP at Kala Amb.

Whereas, a virtual meeting through video conferencing was held on 26-06-2021 with all the stakeholders for obtaining objections, comments and suggestions. The State Board after considering the above objections, comments and suggestions in the meeting and scrutinizing the proposal, keeping in view the detailed project report of CETP, Kala Amb, has finalized the following inlet quality standards for the proposed CETP to be established at Village Ogli, Nahan Road, Kala Amb, Tehsil Nahan, Distt.Sirmour, HP:

Sr.No.	Name of the Parameter	Standards(in mg/l)
1.	Total Suspended Solids(TSS)	500 mg/l
2.	Chemical Oxygen Demand (COD)	1500 mg/l
3.	Biological Oxygen Demand (BOD)	500 mg/l
4.	Oil & Grease	30 mg/l
5.	Fixed Dissolved Solids(FDS)	3000 mg/l
6.	pH	6.5-9.0

Whereas, the State Board proposes to finalize the above mentioned inlet quality parameters in compliance of the MoEF & CC, Government of India notification dated 01-01-2016. Therefore, any individual/person/industry/project/stakeholder/industries association interested in making any objections/suggestions/comments on the above mentioned proposal, may forward the same in writing for consideration to State Pollution Control Board within a period of 15 days, addressed to the Member Secretary, HPSBCB, Phase-III, Below BCS, New Shimla or send it through e-mail to mshppcb@gmail.com, consenthpspcb@gmail.com.

Apoorv Devgan, IAS

Member Secretary

HP State Pollution Control Board, Shimla