

PCB ID 21291 - Baddi Infrastructures (CETP) Sampling Results

Samp ID & Dt	Type	BOD	COD	O&G	P.H	S.S	SOL	SUL
Permissible Values		30 mg/l	250 mg/l	10 mg/l	5.5-9	100 mg/l	2100 mg/l	2 mg/l
45957-08/03/2017	ROU	26.0 mg/l	164.0 mg/l	1.08 mg/l	7.87	26.6 mg/l	2020.0 mg/l	0.64 mg/l
45878-28/02/2017	ROU	8.5 mg/l	88.0 mg/l	1.12 mg/l	7.30	44.8 mg/l	1912.0 mg/l	0.32 mg/l
45814-23/02/2017	ROU	20.0 mg/l	160.0 mg/l	1.08 mg/l	6.99	47.8 mg/l	2082.0 mg/l	0.32 mg/l
45645-13/02/2017	ROU	22.0 mg/l	128.0 mg/l	0.88 mg/l	7.26	25.1 mg/l	2052.0 mg/l	0.32 mg/l
45509-01/02/2017	ROU	24.0 mg/l	184.0 mg/l	1.04 mg/l	7.76	28.6 mg/l	2020.0 mg/l	0.64 mg/l
45437-24/01/2017	ROU	35.0 mg/l	272.0 mg/l	2.20 mg/l	7.96	158.3 mg/l	2312.0 mg/l	0.96 mg/l
45105-19/12/2016	ROU	20.0 mg/l	140.0 mg/l	1.60 mg/l	7.97	53.9 mg/l	1088.0 mg/l	0.64 mg/l
45093-16/12/2016	ROU	26.0 mg/l	180.0 mg/l	4.48 mg/l	6.42	39.0 mg/l	1020.0 mg/l	1.60 mg/l
44962-03/12/2016	OTH	20.5 mg/l	148.0 mg/l	1.76 mg/l	8.24	31.0 mg/l	1710.0 mg/l	0.32 mg/l
44961-03/12/2016	OTH	23.0 mg/l	148.0 mg/l	1.52 mg/l	8.13	32.0 mg/l	1718.0 mg/l	0.32 mg/l
44929-29/11/2016	ROU	24.0 mg/l	200.0 mg/l	2.16 mg/l	8.35	60.0mg/l	1640.0 mg/l	0.64 mg/l
44729-02/11/2016	ROU	13.5 mg/l	92.0 mg/l	0.24 mg/l	8.41	47.0 mg/l	2070.0 mg/l	Nil
43852-25/08/2016	ROU	24.0 mg/l	184.0 mg/l	3.92 mg/l	8.09	92.0 mg/l	2522.0 mg/l	0.32 mg/l
43613-10/08/2016	ROU	24.0 mg/l	212.0 mg/l	3.12 mg/l	8.48	74.0 mg/l	1912.0 mg/l	1.28 mg/l
43555-08/08/2016	OTH	300.0 mg/l	960.0 mg/l	9.56 mg/l	8.06	64.0 mg/l	8622.0 mg/l	0.64 mg/l
43554-08/08/2016	OTH	940.0 mg/l	2096.0 mg/l	12.08 mg/l	7.37	440.0 mg/l	1718.0 us	1.28 mg/l
43553-08/08/2016	OTH	185.0 mg/l	680.0 mg/l	5.40 mg/l	7.83	87.0 mg/l	2760.0 us	0.64 mg/l
43552-08/08/2016	OTH	18.0 mg/l	84.0 mg/l	1.28 mg/l	7.89	43.0 mg/l	2054.0 mg/l	0.32 mg/l
43517-04/08/2016	ROU	30.0 mg/l	220.0 mg/l	2.56 mg/l	7.63	54.0 mg/l	2040.0 mg/l	0.32 mg/l
43424-27/07/2016	ROU	26.0 mg/l	200.0 mg/l	2.88 mg/l	8.25	46.0 mg/l	2470.0 mg/l	0.32 mg/l
43375-22/07/2016	ROU	26.0 mg/l	188.0 mg/l	2.84 mg/l	9.47	29.0 mg/l	2920.0 mg/l	0.64 mg/l
43319-20/07/2016	ROU	26.0 mg/l	120.0 mg/l	4.24 mg/l	8.98	38.0 mg/l	2010.0 mg/l	0.32 mg/l
43304-19/07/2016	ROU	28.0 mg/l	210.0 mg/l	1.12 mg/l	9.63	80.0 mg/l	2160.0 mg/l	0.32 mg/l
43298-18/07/2016	ROU	26.0 mg/l	200.0 mg/l	1.44 mg/l	9.53	78.0 mg/l	2080.0 mg/l	0.32 mg/l
43281-16/07/2016	ROU	30.0 mg/l	212.0 mg/l	1.88 mg/l	9.07	90.0 mg/l	2100.0 mg/l	0.32 mg/l
43274-15/07/2016	ROU	28.0 mg/l	216.0 mg/l	0.72 mg/l	9.92	92.0 mg/l	2006.0 mg/l	0.32 mg/l