

**HPPCB ID: 10159****Bhandari Deepak Industries Private Limited**

<b>DATE</b>	<b>Suspended Solids (Permissible Value= 100)</b>	<b>BOD (Permissible Value= 30)</b>	<b>COD (Permissible Value= 250)</b>	<b>pH (Permissible Value= 5.5 to 9.0)</b>
27-06-2009	16.0 mg/l	1.2 mg/l		8.34
23-07-2009	86.0 mg/l			7.46
30-07-2009		6.0 mg/l		
06-02-2010	18.0 mg/l	3.0 mg/l	32.0 mg/l	7.43
18-05-2010		4.6 mg/l		
21-05-2010	11.0 mg/l			7.36
27-09-2010	42.0 mg/l	18.0 mg/l		7.02
04-03-2011				6.86
08-03-2011	44.0mg/l	57.0mg/l		
05-04-2011				6.73
18-04-2011	34.0 mg/l	20.0 mg/l		
05-08-2011				6.73
29-08-2011	267.0mg/l			
30-08-2011		165.0 mg/l		
05-09-2011				7.7
24-09-2011	30.0 mg/l	9.0 mg/l		
16-02-2012	15.0 mg/l	1.8mg/l		7.24
21-02-2013			1416.0 mg/l	6.39
21-02-2013			1408.0 mg/l	6.88
21-02-2013			20.0 mg/l	7.53
28-02-2013	1408.0 mg/l			
28-02-2013	1004.0 mg/l			
28-02-2013	11.0 mg/l			
01-03-2013		920.0mg/l		
01-03-2013		640.0mg/l		
01-03-2013		3.0mg/l		
24-04-2013	184.0 mg/l	190.0 mg/l	436.0 mg/l	7.61
04-06-2013	29.0 mg/l	28.0 mg/l	184.0 mg/l	8.21
28-02-2015	58.0 mg/l	14.0 mg/l	60.0 mg/l	7.23

## HPPCB ID: 10022

## Ruchira Papers Ltd (Kraft Paper Unit)

DATE	Suspended Solids (Permissible Value= 100)	BOD (Permissible Value= 30)	COD (Permissible Value= 250)	pH (Permissible Value= 5.5 to 9.0)
23-06-2009	55.0 mg/l		376.0 mg/l	7.57
29-06-2009		95.0 mg/l		
07-08-2009	135.0 mg/l	65.0 mg/l	448.0 mg/l	7.13
18-08-2009	93.0 mg/l	45.0 mg/l	392.0 mg/l	7.03
30-09-2009	45.0 mg/l	25.0 mg/l	192.0 mg/l	7.26
07-11-2009	76.0 mg/l	20.0 mg/l	256.0 mg/l	7.65
19-12-2009	36.0 mg/l	7.0 mg/l	104.0 mg/l	7.69
14-01-2010	178.0 mg/l	50.0 mg/l	408.0 mg/l	8.13
22-02-2010	16.0 mg/l			7.37
22-04-2010	171.0 mg/l	90.0 mg/l	448.0 mg/l	7.49
22-04-2010		11.0 mg/l	120.0 mg/l	
31-05-2010	113.0 mg/l	60.0 mg/l	552.0 mg/l	6.61
31-05-2010	566.0 mg/l	75.0 mg/l	480.0 mg/l	6.57
29-07-2010	76.0 Mg/l	14.0 mg/l	192.0 Mg/l	6.89
29-07-2010		40.0 mg/l		5.85
31-07-2010	324.0 mg/l		456.0 mg/l	
08-09-2010	60.0 mg/l	19.0 mg/l	184.0 mg/l	7.71
09-11-2010	171.0 mg/l	75.0 mg/l	496.0 mg/l	8.03
09-11-2010	74.0 mg/l	52.0 mg/l	336.0 mg/l	7.84
07-01-2011	570.0 mg/l	165.0 mg/l	960.0 mg/l	8.3
15-02-2011	80.00 mg/l	140.0 mg/l	744.0 mg/l	7.54
16-04-2011	308.0 mg/l	90.0 mg/l	856.0 mg/l	8.43
26-04-2011	187.0 mg/l	140 mg/l	624.0 mg/l	6.85
28-05-2011	69.0 mg/l	38.0 mg/l	368.0 mg/l	7.4
20-06-2011	34.0 mg/l	22.0 mg/l	256.0 mg/l	7.3
08-07-2011	64.0 mg/l	40.0 mg/l	424.0 mg/l	7.02
28-07-2011	19.0 mg/l	5.2 mg/l	56.0 mg/l	6.99
23-08-2011	25.0 mg/l	7.0 mg/l	112.0 mg/l	7.17
19-10-2011	35.0 mg/l	4.2 mg/l	96.0 mg/l	6.96
27-12-2011	42.0 mg/l	22.0 mg/l	224.0 mg/l	7
27-02-2012	3.0 mg/l	9.0 mg/l	128.0 mg/l	6.99
16-04-2012	76.0 mg/l	12.0 mg/l		7.21
18-04-2012			176.0 mg/l	
18-05-2012	50.0 mg/l	40.0 mg/l	320.0 mg/l	7.5
12-07-2012	40.0 mg/l	20.0 mg/l	280.0 mg/l	5.92
18-08-2012	47.0 mg/l	10.0 mg/l	144.0 mg/l	6.04
13-09-2012	57.0 mg/l	8.0 mg/l	80.0 mg/l	7.56
10-10-2012			336.0 mg/l	
01-11-2012	45.0 mg/l	40.0 mg/l		7.33
05-11-2012	48.0 mg/l	4.2 mg/l	40.0 mg/l	6.4
26-12-2012	6/0 mg/l	1.2 mg/l	8.0 mg/l	6.7
29-01-2013	34.0 mg/l	16.0 mg/l	136.0 mg/l	6.72
14-03-2013	68.0 mg/l	38.0 mg/l	320.0 mg/l	6.49
09-04-2013	89.0 mg/l	44.0 mg/l	336.0 mg/l	6.3
18-05-2013	103.0 mg/l	78.0 mg/l	512.0 mg/l	6.88
18-05-2013	47.0 mg/l	44.0 mg/l	296.0 mg/l	7.63
14-06-2013			104.0 mg/l	
19-06-2013	8.0mg/l	13.0 mg/l		7.31
16-07-2013	33.0 mg/l	2.6 mg/l		7.28
17-07-2013			32.0 mg/l	
27-07-2013	10.0 mg/l	26.0 mg/l	248.0 mg/l	8.35
29-08-2013	4.0 mg/l	8.8 mg/l		8.35
04-09-2013			104.0 mg/l	
20-09-2013	204.0 mg/l	170.0 mg/l	928.0 mg/l	6.09
15-10-2013	41.0 mg/l	17.0 mg/l	144.0 mg/l	6.42
28-11-2013	31.0 mg/l	24.0 mg/l		6.88
20-12-2013			232.0 mg/l	
20-12-2013	59.0 mg/l	14.0 mg/l	168.0 mg/l	7.35

**HPPCB ID: 10828**

**Ruchira Papers Limited (Writing And Printing Unit)**

<b>DATE</b>	<b>Suspended Solids (Permissible Value= 100)</b>	<b>BOD (Permissible Value= 30)</b>	<b>COD (Permissible Value= 250)</b>	<b>pH (Permissible Value= 5.5 to 9.0)</b>
23-06-2009	87.0 mg/l		384.0 mg/l	7.27
29-06-2009		105.0 mg/l		
07-08-2009	188.0 mg/l	80.0 mg/l	496.0 mg/l	7.67
18-08-2009	88.0 mg/l	24.0 mg/l	336.0 mg/l	7.28
30-09-2009				6.88
07-11-2009	117.0 mg/l	195.0 mg/l	712.0 mg/l	
07-11-2009	59.0 mg/l	23.0 mg/l	272.0 mg/l	6.98
19-12-2009	145.0 mg/l	110.0 mg/l	640.0 mg/l	6.45
14-01-2010	59.0 mg/l	18.0 mg/l	256.0 mg/l	7.7
22-02-2010	26.0 mg/l			7.85
22-04-2010		17.0 mg/l	216.0 mg/l	
22-04-2010	56.0 mg/l	22.0 mg/l	184.0 mg/l	7.35
31-05-2010	37.0 mg/l	15.0 mg/l	184.0 mg/l	7.4
31-05-2010	199.0 mg/l	70.0 mg/l	400.0 mg/l	7.25
29-07-2010	55.0 Mg/l	34.0 mg/l	232.0 Mg/l	7.06
08-09-2010	78.0 mg/l	94.0 mg/l	368.0 mg/l	7.25
09-11-2010	6.0 mg/l	130.0 mg/l	968.0 mg/l	8.65
09-11-2010		80.0 mg/l		7.02
19-11-2010	67.0 mg/l		488.0 mg/l	
07-01-2011	470.0 mg/l	90.0 mg/l	784.0 mg/l	7.36
15-02-2011	50.0 mg/l	95.0 mg/l	576.0 mg/l	7.35
16-04-2011	302.0 mg/l	270.0 mg/l	1216.0 mg/l	7.21
26-04-2011	119.0 mg/l	145.0 mg/l	816.0 mg/l	6.76
10-06-2011	77.0 mg/l	58.0 mg/l	384.0 mg/l	7.4
08-07-2011	112.0 mg/l	170.0 mg/l	936.0 mg/l	6.65
07-10-2011	118.0 mg/l	230.0 mg/l	1216.0 mg/l	6.74
27-12-2011	23.0 mg/l	7.0 mg/l	128.0 mg/l	7
27-02-2012	26.0 mg/l	3.6 mg/l	48.0 mg/l	
16-04-2012	80.0 mg/l	24.0 mg/l		7.1
18-04-2012			232.0 mg/l	
18-05-2012	69.0 mg/l	38.0 mg/l	312.0 mg/l	7.04
12-07-2012	5.0 mg/l	12.0 mg/l	160.0 mg/l	6.02
18-08-2012	34.0 mg/l	2.0 mg/l	32.0 mg/l	5.9
13-09-2012	47.0 mg/l	3.6 mg/l	80.0 mg/l	6.83
19-09-2012	98.0 mg/l	110.0 mg/l	744.0 mg/l	6.21
19-09-2012	215.0 mg/l	430.0 mg/l	2080.0 mg/l	6.45
19-09-2012	97.0 mg/l	190.0 mg/l	1152.0 mg/l	6.33
10-10-2012			12.0 mg/l	
01-11-2012	15.0 mg/l	14.0 mg/l		7.03
05-11-2012	8.0 mg/l	4.0 mg/l	40.0 mg/l	7.2
26-12-2012	12.0 mg/l	9.0 mg/l	129.0 mg/l	6.1
29-01-2013	288.0 mg/l	135.0 mg/l	704.0 mg/l	6.18
14-03-2013	42.0 mg/l	24.0 mg/l	248.0 mg/l	6.42
28-03-2013	890.0 mg/l	1300.0 mg/l		3.94
28-03-2013	1420.0 mg/l	1450.0 mg/l		4.09
29-03-2013			3600.0 mg/l	
29-03-2013			3760.0 mg/l	
09-04-2013	79.0 mg/l	64.0 mg/l	504.0mg/l	6.25
20-12-2013	20.0 mg/l	18.0 mg/l	192.0 mg/l	7.32
03-02-2014	54.0 mg/l			7.15
03-02-2014	50.0 mg/l	20.0 mg/l		7.05
06-02-2014		68.0 mg/l	408.0 mg/l	
06-02-2014			192.0 mg/l	
07-03-2014		19.0 mg/l	176.0 mg/l	
11-03-2014	12.0 mg/l			6.92
31-03-2014	44.0 mg/l	14.0 mg/l		6.73
01-04-2014			160.0 mg/l	
09-04-2014	23.0 mg/l			6.96
16-04-2014			16.0 mg/l	
26-04-2014	6.0 mg/l			6.67
03-05-2014		11.0 mg/l	144.0 mg/l	
09-06-2014	45.0 mg/l			6.6

11-06-2014		15.0 mg/l	104.0 mg/l	
01-07-2014	8.0 mg/l			5.75
02-07-2014		10.0 mg/l	128.0 mg/l	
02-08-2014	32.0 mg/l			6.97
04-08-2014		16.0 mg/l	184.0 mg/l	
14-08-2014	38.0 mg/l	28.0 mg/l	240.0 mg/l	7.47
09-10-2014	69.0 mg/l	24.0 mg/l	216.0 mg/l	7.96
28-10-2014	12.0 mg/l	15.0 mg/l		8.32
29-10-2014			144.0 mg/l	
20-11-2014	53.0 mg/l			7.16
21-11-2014			232.0 mg/l	
04-12-2014		24.0 mg/l		
22-12-2014	39.0 mg/l	14.0 mg/l	120.0 mg/l	7.16
30-01-2015	22.0 mg/l	15.0 mg/l	168.0 mg/l	6.86
24-02-2015	24.0 mg/l	26.0 mg/l	240.0 mg/l	7.37
11-05-2015	34.0 mg/l			8.31
18-05-2015	59.0 mg/l			7.14
23-05-2015		36	192	
08-06-2015		28	240	
04-07-2015	88	24	136	7.8
10-08-2015	92	20	80	7.6
27-08-2015	88			7.05
28-08-2015		24	96	
19-09-2015	20			7.4
21-09-2015		14		
23-09-2015			160.0 mg/l	
31-10-2015	16.0 mg/l	3.2 mg/l	80.0 mg/l	7.27
02-12-2015	36.0 mg/l	20.0 mg/l	160.0 mg/l	7.75
08-01-2016	24.0 mg/l	80.0 mg/l	296.0 mg/l	7.6
02-02-2016	11.0 mg/l	8.0 mg/l	100.0 mg/l	8.15
15-03-2016	30.0 mg/l	10.0 mg/l	80.0 mg/l	7.91
30-03-2016	22.0 mg/l	20.0 mg/l	204.0 mg/l	7.73
12-05-2016	23.0 mg/l	12.0 mg/l	76.0 mg/l	7.86
09-06-2016	24.0 mg/l			7.06
15-06-2016		16.0 mg/l	140.0 mg/l	
15-07-2016	24.0 mg/l	8.8 mg/l	68.0 mg/l	7.54
02-08-2016	40.0 mg/l	4.0 mg/l	148.0 mg/l	7.53

**HPPCB ID: 11247****Rupana Paper Mills Limited**

<b>DATE</b>	<b>Suspended Solids (Permissible Value= 100)</b>	<b>BOD (Permissible Value= 30)</b>	<b>COD (Permissible Value= 250)</b>	<b>pH (Permissible Value= 5.5 to 9.0)</b>
14-07-2009	82.0mg/l			6.64
15-07-2009		16.0 mg/l		
16-07-2009				6.82
17-07-2009	162.0 mg/l			
23-07-2009	528.0 mg/l			6.77
23-07-2009	697.5 mg/l	50.0 mg/l		6.72
30-07-2009		250.0 mg/l		
30-07-2009		280.0 mg/l		
03-09-2009				7.68
08-09-2009	46.0 mg/l			
11-09-2009		6.0 mg/l		
13-10-2009		4.8 mg/l		
14-10-2009	22.0 mg/l			7.38
02-12-2009	28.0 mg/l			7.58
20-12-2009		1.2 mg/l		
08-04-2010		94.0 mg/l		
09-04-2010	252.0 mg/l			6.98
25-05-2010	110.0 mg/l			7.09
25-05-2010	132.0 mg/l			6.79
28-05-2010		90.0 mg/l		
28-05-2010		172.5 mg/l		
17-07-2010				7.73
20-07-2010	31.0 mg/l			
21-07-2010		1.8 mg/l		
25-08-2010	44.0 mg/l			7.24
25-08-2010	273.0 mg/l			6.97
25-08-2010	4.0 mg/l			7.42
27-08-2010		8.0 mg/l		
27-08-2010		110.0 mg/l		
27-08-2010		0.8 mg/l		
28-08-2010			8.0 mg/l	
07-10-2010	5.0 mg/l		64.0 mg/l	7.17
07-10-2010	5.0 mg/l		12.0 mg/l	7.54
08-10-2010		8.0 mg/l		
08-10-2010		2.0 mg/l		

**HPPCB ID: 12301****Haripur Paper Company**

<b>DATE</b>	<b>Suspended Solids (Permissible Value= 100)</b>	<b>BOD (Permissible Value= 30)</b>	<b>COD (Permissible Value= 250)</b>	<b>pH (Permissible Value= 5.5 to 9.0)</b>
14-07-2009	12.0mg/l			7.33
23-07-2009		8.0 mg/l		
29-08-2011				7.49
24-09-2011	75.0 mg/l	19.0 mg/l		
22-03-2012	161.0 mg/l			6.67
24-03-2012		300.0 mg/l		
07-06-2012	632.0mg/l			6.66
13-06-2012		480.0mg/l		
15-09-2012				7.01
22-09-2012		580.0mg/l		
01-10-2012	92.0 mg/l			
10-12-2013				7.19
17-12-2013	43.0 mg/l	50.0 mg/l		

**HPPCB ID: 10151****Pragati Papers Ind Ltd**

<b>DATE</b>	<b>Suspended Solids (Permissible Value= 100)</b>	<b>BOD (Permissible Value= 30)</b>	<b>COD (Permissible Value= 250)</b>	<b>pH (Permissible Value= 5.5 to 9.0)</b>
19-05-2011	168.0 mg/l	210.0 mg/l		
20-05-2011			848.0 mg/l	6.73
20-06-2011	5.0 mg/l	2.8 mg/l	40.0 mg/l	7

**HPPCB ID: 12840**

**Jassar Papers Pvt. Ltd.**

<b>DATE</b>	<b>Suspended Solids (Permissible Value= 100)</b>	<b>BOD (Permissible Value= 30)</b>	<b>COD (Permissible Value= 250)</b>	<b>pH (Permissible Value= 5.5 to 9.0)</b>
09-12-2010	53.0mg/l			7.17
14-12-2010		310.0mg/l	420.0mg/l	
10-01-2011	44.0mg/l	29.0mg/l	120.0mg/l	7.47
01-03-2011	18.0mg/l	22.0mg/l	76.0mg/l	7.28
05-09-2012			16.0 mg/l	7.14
12-09-2012	32.0mg/l			
15-09-2012		4.2mg/l		



**HPPCB ID: 10094****Saber Papers Ltd.**

<b>DATE</b>	<b>Suspended Solids (Permissible Value= 100)</b>	<b>BOD (Permissible Value= 30)</b>	<b>COD (Permissible Value= 250)</b>	<b>pH (Permissible Value= 5.5 to 9.0)</b>
15-07-2010				7.31
23-07-2010	7.0mg/l	10.0mg/l	32.0mg/l	
28-12-2010	15.0mg/l		64.0mg/l	7.49
06-01-2011		13.0mg/l		
11-03-2011	129.0mg/l		308.0mg/l	6.75
16-03-2011		145.0mg/l		
25-05-2011	68.0mg/l	150.0mg/l	320.0mg/l	6.78
23-08-2011	96.0mg/l	84.0mg/l	244.0mg/l	8.29
16-09-2011	253.2mg/l	ND	128.0mg/l	7.85
07-10-2011	2.0mg/l		576.0mg/l	7.59
14-10-2011		220.0mg/l		
22-10-2011			4.0 mg/l	8.27
25-10-2011	3.0mg/l	0.30mg/l		
07-03-2012			4.0 mg/l	8.14
07-03-2012			116.0 mg/l	8.08
15-03-2012	0.2mg/l	0.9mg/l		
15-03-2012	1.0mg/l	32.0mg/l		

**HPPCB ID: 18753****Borker Packaging Pvt. Ltd**

<b>DATE</b>	<b>Suspended Solids (Permissible Value= 100)</b>	<b>BOD (Permissible Value= 30)</b>	<b>COD (Permissible Value= 250)</b>	<b>pH (Permissible Value= 5.5 to 9.0)</b>
15-09-2012	49.0 mg/l			7.35
19-09-2012			88.0 mg/l	
20-09-2012		10.0mg/l		
29-03-2013			296.0 mg/l	7.62
04-04-2013	111.0 mg/l			
05-04-2013		80.0 mg/l		

**HPPCB ID: 10049****Sainsons Pulp & Paper Ltd.**

<b>DATE</b>	<b>Suspended Solids (Permissible Value= 100)</b>	<b>BOD (Permissible Value= 30)</b>	<b>COD (Permissible Value= 250)</b>	<b>pH (Permissible Value= 5.5 to 9.0)</b>
19-05-2010	14.0 mg/l			6.93
25-05-2010		9.6 mg/l	52.0 mg/l	
23-07-2010	4.0mg/l		72.0mg/l	7.17
28-07-2010		9.0mg/l		
27-09-2010	100.0mg/l	35.0mg/l	184.0mg/l	6.73

**HPPCB ID: 12305****Shankar Board Processor Unit - II**

<b>DATE</b>	<b>Suspended Solids (Permissible Value= 100)</b>	<b>BOD (Permissible Value= 30)</b>	<b>COD (Permissible Value= 250)</b>	<b>pH (Permissible Value= 5.5 to 9.0)</b>
01-07-2009	1160.0mg/l	1050.0mg/l	2064.0mg/l	6.12
09-12-2010	245.0mg/l		2680.0mg/l	6.55
09-12-2010	218.0mg/l		280.0mg/l	6.72
13-12-2010		1125.0mg/l		
13-12-2010		110.0mg/l		
08-02-2011	394.0mg/l		3360.0mg/l	5.58
26-02-2011		900.0mg/l		
01-03-2011	199.0mg/l		308.0mg/l	7.55
07-03-2011		145.0mg/l		
04-04-2011	37.0mg/l	9.0mg/l	24.0mg/l	7.76
08-04-2011	15.0mg/l	10.0mg/l	28.0mg/l	7.65
23-04-2011	18.0mg/l	20.0mg/l	48.0mg/l	6.98
07-10-2011	42.0mg/l		8.0mg/l	7.74
15-10-2011		3.0mg/l		
18-02-2012			76.0 mg/l	7.95
21-02-2012	37.4mg/l	30.0mg/l		
05-09-2012			160.0 mg/l	7.43
12-09-2012	22.0mg/l	58.0mg/l		
22-07-2014	8.0 mg/l			
23-07-2014		54.0 mg/l		
30-07-2014			136.0mg/l	8.39

**HPPCB ID: 15215**

**Shivalik Fibers**

<b>DATE</b>	<b>Suspended Solids (Permissible Value= 100)</b>	<b>BOD (Permissible Value= 30)</b>	<b>COD (Permissible Value= 250)</b>	<b>pH (Permissible Value= 5.5 to 9.0)</b>
15-03-2016	30.mg/l	16.0 mg/l	180.0 mg/l	7.35

**HPPCB ID: 14403****Pinetree Packaging Pvt. Ltd.**

<b>DATE</b>	<b>Suspended Solids (Permissible Value= 100)</b>	<b>BOD (Permissible Value= 30)</b>	<b>COD (Permissible Value= 250)</b>	<b>pH (Permissible Value= 5.5 to 9.0)</b>
30-04-2011				6.81
13-05-2011	86.0 mg/l			
16-05-2011		44.0 mg/l		
17-05-2011			240.0mg/l	
05-06-2013	27.0 mg/l	4.0 mg/l	12.0 mg/l	7.62
31-03-2014	12.0 mg/l	10.0 mg/l	48.0 mg/l	6.84
16-07-2015	88.0 mg/l	20.0 mg/l	120.0 mg/l	6.67
24-07-2015	10.0 mg/l			7.28
13-08-2015			20 mg/l ± 2.0 mg/l*	
18-08-2015		2.5 mg/l ± 0.15 mg/l*		

**HPPCB ID: 18760**

**Ravlak Technologies Private Limited**

<b>DATE</b>	<b>Suspended Solids (Permissible Value= 100)</b>	<b>BOD (Permissible Value= 30)</b>	<b>COD (Permissible Value= 250)</b>	<b>pH (Permissible Value= 5.5 to 9.0)</b>
03-12-2015				7.48
09-12-2015	92.0 mg/l	24.0 mg/l	200.0 mg/l	
01-03-2016	86.0 mg/l	28.0 mg/l	184.0 mg/l	
09-03-2016				7.8

**HPPCB ID: 10271**

**Janus Packaging (P) Limited**

<b>DATE</b>	<b>Suspended Solids (Permissible Value= 100)</b>	<b>BOD (Permissible Value= 30)</b>	<b>COD (Permissible Value= 250)</b>	<b>pH (Permissible Value= 5.5 to 9.0)</b>
25-10-2013	17.0 mg/l	3.0 mg/l		



**HPPCB ID: 10603****M B D Printographics Pvt. Ltd. ( Paper Manufacturing)**

<b>DATE</b>	<b>Suspended Solids (Permissible Value= 100)</b>	<b>BOD (Permissible Value= 30)</b>	<b>COD (Permissible Value= 250)</b>	<b>pH (Permissible Value= 5.5 to 9.0)</b>
06-05-2010	125.0 mg/l	200.0 mg/l	448.0 mg/l	6.97
30-06-2010	157.0mg/l		864.0mg/l	6.73
15-07-2010		320.0mg/l		
28-08-2010	247.0mg/l	540.0mg/l	776.0mg/l	5.63
28-12-2010				7.2
06-01-2011	119.0mg/l	180.0mg/l	536.0mg/l	

**HPPCB ID: 19576**

**M\s Micro Mottion India (P) Limited**

<b>DATE</b>	<b>Suspended Solids (Permissible Value= 100)</b>	<b>BOD (Permissible Value= 30)</b>	<b>COD (Permissible Value= 250)</b>	<b>pH (Permissible Value= 5.5 to 9.0)</b>
07-03-2014		145.0 mg/l	688.0 mg/l	
11-03-2014	77.0 mg/l			7.12

**HPPCB ID: 13142****Claridge Moulded Fibre Ltd (Unit I)**

<b>DATE</b>	<b>Suspended Solids (Permissible Value= 100)</b>	<b>BOD (Permissible Value= 30)</b>	<b>COD (Permissible Value= 250)</b>	<b>pH (Permissible Value= 5.5 to 9.0)</b>
14-01-2013				6.99
14-01-2013				7.02
22-01-2013			1648.0 mg/l	
22-01-2013			3152.0 mg/l	
23-01-2013	194.0 mg/l	1080.0 mg/l		
23-01-2013	154.0 mg/l	1100.0 mg/l		

**HPPCB ID: 10417**

**Concept Cartonz Private Limited**

<b>DATE</b>	<b>Suspended Solids (Permissible Value= 100)</b>	<b>BOD (Permissible Value= 30)</b>	<b>COD (Permissible Value= 250)</b>	<b>pH (Permissible Value= 5.5 to 9.0)</b>
25-06-2009	6.0 mg/l	24.0 mg/l	148.0 mg/l	7.75
17-04-2015	10.0 mg/l	1.0 mg/l	20.0 mg/l	7.03